



パイプ 外径	D	A	B	T	C		S 最小	D	A	T
					基準寸法	許容差				
4.76	4.76	6.6~7.1	3.0~3.7	0.7(0.8)	1.4(1.6)	±0.2	1	4.76	6.2~6.8	0.8
6.35	6.35	8.6~9.1	4.5~5.2	0.7(0.8)	1.4(1.6)		1	6.35	8.1~8.7	0.8
8	8	10.5~11.0	6.2~6.9	0.7(1)	1.4(2)		1.6	8	10.0~10.6	1
10	10	13.0~13.5	8.2~8.9	0.7(1)	1.4(2)		1.6	10	12.1~12.7	1
12	12	15.0~15.7	9.8~10.5	0.9(1)	1.8(2)		1.6	12	14.7~15.3	1
12.7	12.7	15.6~16.3	10.3~11.0	0.9	1.8		1.6	—	—	—
15	15	18.1~18.8	12.7~13.4	1	2		1.6	—	—	—
適用管 の種類	二重巻鋼管, 一重巻鋼管, 機械構造用炭素鋼鋼管, りん脱酸銅継目無管							りん脱酸銅継目無管		